Ref. Certif. No.

CN59447

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Residual Current Operated Circuit-breaker With Integral Overcurrent Protection
Name and address of the applicant	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Name and address of the manufacturer	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Name and address of the factory Note: *When more than one factory, please report on page 2*	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Ratings and principal characteristics	Uimp: 4kV;Ui: 500V;Ue: AC230V;In: 6A, 10A, 16A, 20A, 25A, 32A, 40A; Instantaneous tripping current: Type B, Type C;IΔn: 30mA;Type of RCBO: Type AC, Type A; Electronic type; IΔm: 500A;Icn=Ics: 6000A;Number of poles: 1P+N (1 protected poles with a switched neutral pole)
Trademark / Brand (if any)	CHINT
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	NB2LE-40ZT, NB2LE-40ZTB;
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 61009-2-2:1991(1st Edition);IEC 61009-1:2010, IEC 61009-1:2010/AMD1:2012, IEC 61009-1:2010/AMD2:2013
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2022CQC-104535

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: http://www.cqc.com.cn

Date: Apr.04,2023

Signature: 谢肇煦
Xie ZhaoXu

CB 0071610