

IEC

IECEE



TM

Ref. Certif. No.

CN66205

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Moulded Case Circuit-breakers

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Note: When more than one factory, please report on page 2

Wenzhou CHINT Electrics Technology Co., Ltd.
No.1318 Binhai No.2 Avenue, Economic and
Technical Development Zone, Wenzhou City, Zhejiang
Province, P.R.China

Ratings and principal characteristics

See the Appendix

Trademark (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

NXM-1250S,H,NXMH-1250S,H,NXMP-1250S,H,NXMF-125
0S,H,
NXMS-1250S,H,NXMSH-1250S,H,NXMSP-1250S,H,NXMS
F-1250S,H ;Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity withIEC 60947-2:2016/AMD1:2019;IEC 60947-2:2016(5th
Edition);IEC 60947-1:2007;IEC
60947-1:2007/AMD1:2010;IEC 60947-1:2007/AMD2:2014As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2024CQC-114439

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Jun.18,2024

Signature:

谢肇煦

Xie ZhaoXu



NXM-1250S,H,NXMH-1250S,H,NXMP-1250S,H,NXMF-1250S,H,
NXMS-1250S,H,NXMSH-1250S,H,NXMSP-1250S,H,NXMSF-1250S,H ;
Uimp:12kV;
Ui:1000V;
Ue: Type S:AC220V/230V/240V,AC380V/400V/415V;
Type H:AC220V/230V/240V,AC380V/400V/415V,660V/AC690V;
In: Electronic: 1250A;
In: Thermo-magnetic,electromagnetic:1000A,1250A;
Over-current release:Thermo-magnetic,electromagnetic, electronic;
Type S:AC220V/230V/240V:Ics=50kA,Icu=75kA;AC380V/400V/415V:Ics=36kA,Icu=50kA;
Type H:AC220V/230V/240V:Ics=75kA,Icu=100kA;AC380V/400V/415V:Ics=50kA,Icu=70kA;
660V/AC690V:Ics=20kA,Icu=30kA;
Icw:19.2kA/1s (only electronic) ;
50/60Hz;
Selectivity category: A (thermo-magnetic, electromagnetic), B (electronic);
Poles:3P,3P+N(3 protected poles with an uninterrupted neutral pole),
4P(3 protected poles with a switched neutral pole) ,4P;
Applicable for isolation(except 3P+N(3 protected poles with an uninterrupted neutral pole));
Auxiliary contacts:AX-8/M8;1NO1NC,2NO2NC;
Ith:2.5A;
AC-15:Ue:AC380V/400V/415V,Ie:0.47A;
DC-13:Ue:DC220V/240V;Ie:0.27A;
Electronic Accessories complied with Annex N:
Undervoltage release:UVT-M7:AC220V/230V/240V ,AC380V/400V/415V;
Motor-operator:MD-M7:AC220V/230V/240V,AC380V/400V/415V ,DC110V,DC220V/250V


Page 1 of 1

Additional information (if necessary)

Date:

Jun.18,2024

Signature:


Xie ZhaoXu



CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

CERTIFICATE OF CONFORMITY

Certificate No.: CE240303008960

Product

Moulded Case Circuit-breakers

Applicant

Zhejiang CHINT Electric Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Type/Model

NXM-1250S,H,NXMH-1250S,H,NXMP-1250S,H,NXMF-1250S,H,
NXMS-1250S,H,NXMSH-1250S,H,NXMSP-1250S,H,NXMSF-1250S,H ;

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2024CQC0303-014824, the submitted sample(s) of the above item complies with:

EN 60947-2:2017/A1:2020;EN 60947-2:2017

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Jun.18,2024

Valid until: Jun.17,2027

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE240303008960

NXM-1250S,H,NXMH-1250S,H,NXMP-1250S,H,NXMF-1250S,H,
NXMS-1250S,H,NXMSH-1250S,H,NXMSP-1250S,H,NXMSF-1250S,H ;
Uimp:12kV;
Ui:1000V;
Ue: Type S:AC220V/230V/240V,AC380V/400V/415V;
Type H:AC220V/230V/240V,AC380V/400V/415V,660V/AC690V;
In: Electronic: 1250A;
In: Thermo-magnetic,electromagnetic:1000A,1250A;
Over-current release:Thermo-magnetic,electromagnetic, electronic;
Type S:AC220V/230V/240V:Ics=50kA,Icu=75kA;AC380V/400V/415V:Ics=36kA,Icu=50kA;
Type H:AC220V/230V/240V:Ics=75kA,Icu=100kA;AC380V/400V/415V:Ics=50kA,Icu=70kA;
660V/AC690V:Ics=20kA,Icu=30kA;
Icw:19.2kA/1s (only electronic) ;
50/60Hz;
Selectivity category: A (thermo-magnetic, electromagnetic), B (electronic);
Poles:3P,3P+N(3 protected poles with an uninterrupted neutral pole),
4P(3 protected poles with a switched neutral pole) ,4P;
Applicable for isolation(except 3P+N(3 protected poles with an uninterrupted neutral pole));
Auxiliary contacts:AX-8/M8;1NO1NC,2NO2NC;
Ith:2.5A;
AC-15:Ue:AC380V/400V/415V,Ie:0.47A;
DC-13:Ue:DC220V/240V;Ie:0.27A;
Electronic Accessories complied with Annex N:
Undervoltage release:UVT-M7:AC220V/230V/240V ,AC380V/400V/415V;
Motor-operator:MD-M7:AC220V/230V/240V,AC380V/400V/415V ,DC110V,DC220V/250V



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE